

Confirmation

LEED

On 22 July 2019, Eurofins Product Testing A/S received a sample of a panel with the product name:

ARCHISONIC®

supplied by

Impact Acoustic AG

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516 and CDPH 01350 testing standards (See test report no. 392-2019-00296601_H_EN_02).

The test results of the tested product indicate that the product qualifies for LEED v4 specifications on VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017 (worst case relative to v1.0-2010)); and a TVOC below 0.5 mg/m³ in both office and class room.

12 September 2019



Maria Pelle Madsen
Analytical Chemist

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.

Confirmation

LEED